

3. How do these procedures apply to mobile home replacements in licensed mobile home parks?

Answer: These procedures do not apply to replacements in mobile home parks. These parks should be checked for compliance with their permits during routine park inspections and action taken to correct any violations noted.

4. A structure has been destroyed by fire or other natural disaster and the applicant is rebuilding the same floorplan. What action is required?

Answer: The applicant must submit an application with a proposed site plan and floor plan. Follow the procedures noted in 1. and 2. above for mobile home replacements.

5. What if a registered septic tank contractor conducts the site evaluation for an existing system inspection?

Answer: If a site visit is not required by our department, only a \$25 application and plan review fee is required.

6. If an applicant is replacing a mobile home with one of the same size and number of bedrooms, may an outlet filter be required?

Answer: An outlet filter may not be required in such cases.

7. If an establishment is already exceeding the design flow limitations on an existing system, is the replacement a new system or a modification?

Answer: A new system meeting all current standards and new system permit fees is required.

8. When a commercial change of ownership takes place and DACS or DBPR request an existing system assessment, can the department charge for the inspection?

Answer: Yes, the department can charge for any mandatory, regulatory inspections they are requested to do.

9. Is a permit and inspection required for the installation of an outlet filter?

Answer: Yes, a permit and inspection is required. The \$25 re-inspection fee would be charged to inspect the installation of the outlet filter.

10. Can the applicant elect to put in a new system for an addition to a house and leave the existing system as is?

Answer: While the applicant may elect to put in a new system for the addition, the existing system must still be evaluated for compliance with the rule. In particular, the separation from wet season water table, tank integrity, and outlet filter requirements must be met.

11. Is replacement of sectional lids that do not meet current requirements required on older tanks?